

System Laboratories UK LTD

Classification Report

Fire classification of construction products and building elements - Part 5: Classification using data from external fire exposure to roofs tests

System Laboratories UK
LTD
Unit 13
Apex Park
Leighton Road
Leighton Buzzard
LU7 3RE
United Kingdom


Report Number 2245
Issue A
Prepared for Ryno Ltd
Date 08/06/2026

Issue	Date	Notes
A	08/06/2026	First issue

Prepared by

Name Austin Melton

Position Testing Technician

Signature 

Authorised by

Name Asaf Gitarts

Position Technical Director

Date

Signature

This report is made on behalf of System Laboratories UK LTD and may only be distributed in its entirety, without amendment, and with attribution to System Laboratories UK LTD to the extent permitted by the terms and conditions of the contract. Test results relate only to the specimens tested. System Laboratories UK LTD has no responsibility for the design, materials, workmanship or performance of the product or specimens tested. This report does not constitute an approval, certification or endorsement of the product tested and no such claims should be made on websites, marketing materials, etc. Any reference to the results contained in this report should be accompanied by a copy of the full report, or a link to a copy of the full report.

System Laboratories UK LTD's liability in respect of this report and reliance thereupon shall be as per the terms and conditions of contract with the client and System Laboratories UK LTD shall have no liability to third parties to the extent permitted in law.

Contents

1.	Introduction	4
2.	Details of classified product	5
2.1.	General	5
2.2.	Traceability	5
2.3.	Sample details	5
2.4.	Detailed product description	6
3.	Reports and results in support of this classification	7
3.1.	Reports	7
3.2.	Results	8
4.	Classification and field of application	9
4.1.	Reference of classification	9
4.2.	Classification	9
4.3.	Field of application	9
5.	References	10

DRAFT

1. Introduction

This classification report defines the classification assigned to Fixed Head Adjustable Pedestal System featuring porcelain paving, in accordance with the procedures given in EN 13501-5: 2016.

EXTERNAL EXPOSURE TO FIRE CLASSIFICATION REPORT IN ACCORDANCE WITH EN 13501-5: 2016 test 4

Sponsor: Ryno Ltd
Prepared for: Ryno Ltd
Place of manufacture: Castle Point, Castle Way, Ellon, AB41 9RG

CAB Number: N/A
Classification report No.: 2245-A
Date of issue: 08/06/2026

This classification report may only be used or reproduced in its entirety.

2. Details of classified product

2.1. General

Classification according to EN 13501-5:2016 of Fixed Head Adjustable Pedestal System featuring porcelain paving

2.2. Traceability

The test sample was supplied by the sponsor. System Laboratories UK LTD was not involved in the sampling process and therefore cannot comment upon the relationship between the samples supplied for the test and the products supplied to the market.

2.3. Sample details

Test sponsor	Ryno Ltd Castlepoint Castle Way Ellon AB41 9RG
Place of manufacture	As above
Trade name	Fixed Head Adjustable Pedestal System featuring porcelain paving
Sample description (as provided by sponsor)	Ryno Porcelain paving, installed on RP-FR Non-combustible fixed head adjustable pedestals. The pedestals feature a TPE head spacer gasket, and a 3mm BRSP base rubber shockpad (used primarily for sound absorption and membrane protection) is placed under the pedestal base, on top of the insulation. The system was built on, but not fixed to, a mock roof build up featuring a Euroclass E fire rated XPS insulation and a waterproofed plywood deck.
Product data (as provided by sponsor)	
Generic type of product	Porcelain paving and adjustable pedestal system
Nominal thickness (mm)	200
Density of core (kg/m ³)	2370
Mass per unit area (kg/m ²)	55
Colour	Various
Test face	Porcelain Paving

Flame retardant added, or
organic content limited
during production

No flame retardant added

Substrate and ventilation conditioned

Substrate RPF fixed head adjustable pedestals. Pedestals loose laid onto insulation layer. A 1mm HRSP head rubber shockpad is applied to the head of the pedestals and a 3mm BRSP base rubber shockpad (both shockpads used primarily for sound absorption and membrane protection) is placed under the pedestal base, on top of the insulation. The system was built on, but not fixed to, a mock roof build up featuring a Euroclass E fire rated XPS insulation and a waterproofed plywood

2.4. Detailed product description

The roof/roof covering comprises, top to bottom.

[Layer 1]	Type of product/layer	Ryno Porcelain Tiles and Concrete Paving
	Product/layer reference	Ryno Porcelain Paving
	Thickness	20 mm
	Colour	N/A
	Construction form	porcelain tile loose laid on pedestal support (layer 2)
[Layer 2]	Type of product/layer	Polypropylene paving support pedestals
	Product/layer reference	Fixed head adjustable pedestals
	Thickness	165-235mm adjustment range. Void set to 180mm
	Colour	Black
	Construction form	Pedestals loose laid onto insulation layer. A 1mm HRSP head rubber shockpad is applied to the head of the pedestals and a 3mm BRSP base rubber shockpad (both shockpads used primarily for sound absorption and membrane protection) is placed under the pedestal base, on top of the insulation
[Layer 3]	Type of product/layer	Insulation
	Product/layer reference	Euroclass E fire rated XPS Insulation
	Thickness	50 mm
	Colour	Grey
	Construction form	Loose laid onto waterproofing layer

[Layer 4]	Type of product/layer	Waterproofing layer
	Product/layer reference	Bituminous Felt Membrane
	Thickness	5 mm
	Colour	Black
	Construction form	Loose laid onto 18 mm OSB backing board
Deck	Type of product/layer	18 mm OSB backing board
	Product/layer reference	18 mm OSB backing board
	Thickness	18 mm
	Colour	Natural
	Construction form	18 mm OSB decking

3. Reports and results in support of this classification

3.1. Reports

Name of laboratory	Name of test sponsor	Test report No.	Test method/field of application
System Laboratories UK	Ryno Ltd	2244-A	CEN/TS 1187:2012 - test 4

3.2. Results

Test conditions:	20.2
Test Pitch:	0°
Deck:	18 mm OSB backing board
Supporting structure:	Fixed head pedestals

Stage:	Parameter	Number of tests	Results	
			Continuous parameter mean	Compliance with class B_{ROOF}(t₄)
Preliminary test (Stage 1)	Burn time (s)	1	0 s	< 5 mins Compliant
	Flame Spread distance (m)	1	0 m	< 0.38 m Compliant
	Penetration (Y/N)	1	N	No penetration Compliant
Penetration test (Stage 2):	Penetration time (min)	3	No penetration	No penetration Compliant

4. Classification and field of application

4.1. Reference of classification

This classification has been carried out in accordance with EN 13501-5:2016.

4.2. Classification

The roof/roof covering, Fixed Head Adjustable Pedestal System in relation to its external fire performance is classified:"

External fire performance classification:	B_{ROOF}(t4)
---	-----------------------------

This classification document does not represent type approval or certification of the product.

The laboratory has played no part in sampling of the product.

4.3. Field of application

This classification is valid for the following product and mounting and fixing parameters:

Pitches	0-10°
Decks	No variation allowed
Substrates	No variation allowed
Supporting structure	No variation allowed

5. References

EN 13501-5:2016 - Fire classification of construction products and building elements

CEN/TS 1187:2012 - Test methods for external fire exposure to roofs

DRAFT

-End of Report-